

TG-Corp C3

PI=64,00 kW
KU=0,7
Pmsa=44,80 kW

1	16/0,03A	Iluminat evacuare	1,0/0,7 kW
2	16/0,03A	Iluminat perica N2XH 3x1,5	1,0/0,7 kW
3	16/0,03A	Iluminat 1 parter N2XH3x1,5	1,0/0,7 kW
4	16/0,03A	Iluminat 2 parter N2XH3x1,5	1,0/0,7 kW
5	16/0,03A	Iluminat 3 parter N2XH3x1,5	1,0/0,7 kW
6	16/0,03A	Iluminat 4 parter N2XH3x1,5	1,0/0,7 kW
7	16/0,03A	Prize 1 parter N2XH3x2,5	2,0/1,4 kW
8	16/0,03A	Prize 2 parter N2XH3x2,5	2,0/1,4 kW
9	16/0,03A	Prize 3 parter N2XH3x2,5	2,0/1,4 kW
10	16/0,03A	Prize 4 parter N2XH3x2,5	2,0/1,4 kW
11	16/0,03A	MSV1 N2XH3x2,5	2,0/1,4 kW
12	16/0,03A	MSV2 N2XH3x2,5	2,0/1,4 kW
13	16/0,03A	MSV3 N2XH3x2,5	2,0/1,4 kW
14	16/0,03A	MSV4 N2XH3x2,5	2,0/1,4 kW

15	16/0,03A	MSV5 N2XH3x2,5	2,0/1,4 kW
16	16/0,03A	Prize GS 1 parter N2XH3x2,5	2,0/1,4 kW
17	16/0,03A	Prize GS 2 parter N2XH3x2,5	2,0/1,4 kW
18	16/0,03A	Prize GS 3 parter N2XH3x2,5	2,0/1,4 kW
19	16/0,03A	Prize GS 4 parter N2XH3x2,5	2,0/1,4 kW
20	16/0,03A	Prize GS diz. parter N2XH3x2,5	2,0/1,4 kW
21	16/0,03A	Circuit 1 Ventilcoconvector N2XH3x2,5	2,5/1,75 kW
22	16/0,03A	Circuit 2 Ventilcoconvector N2XH3x2,5	2,5/1,75 kW
23	16/0,03A	Boiler N2XH3x2,5	3,0/2,1 kW
24	16/0,03A	Centrala de detectie - IDSAL N2XH3x2,5	0,5/0,3 kW
25	16/0,03A	Pompa recirculatie N2XH3x2,5	0,5/0,3 kW
26	16/0,03A	Pompa recirculatie N2XH3x2,5	0,5/0,3 kW
27	16/0,03A	Pompa recirculatie N2XH3x2,5	0,5/0,3 kW
28	32/0,03A	Pompa de caldura N2XH5x6	20,0/14,0 kW

Panouri fotovoltaice

78,2/78,2 kW

Invertor Fotovoltaic 125A
N2XH3x50+35 3P+N



TG-Corp C3: Tablou electric general Corp C3 - Cantina

Toate materialele vor avea agrement tehnic si certificat de calitate. Lucrarile se executa de catre electricieni autorizati cu respectarea normativelor in vigoare IT, NTE007/2008 si Normelor specifice de securitate, sanatate in munca si pentru situatii de urgenta PSI in vigoare.
Tabloul se va executa in carcasa din polycarbonat, va avea bare de nul de lucru si nul de protectie, va fi dotat cu sonerie modulara. Disjunctoarele vor avea capacitate de rupere min. 6kA.

RHEIN
BRUCKE

Rheinbrücke SRL
Eugeniu de Savoy Nr. 7
Timisoara 300055 - Romania
Coordonata Fiscale
RO 2806383
J1963000028384
www.rheinbrucke.ro
office@rheinbrucke.ro
T +40 729 142 199

BENEFICIAR
UAT MUNICIPIUL ARAD
DENUMIRE PROIECT
AMENAJARE CAMPUS PREUNIVERSITAR TEHNOLOGIC

PROIECT NR.
699, 2024
FAZA
D.T.A.C. / P.T.H.
rev. 00

SPECIFICATIE	NUME
Seif Proiect	ing. HANZA Augustin Răzvan
Proiectat	ing. Nistor Paul
Proiectat	ing. Bulzan Doru
Desenat	ing. Bobes-Ilici Cosmin

SCARA 1:100	AMPLASAMENT STR. IOAN FLUJERAS Nr. 100, MUNICIPIUL ARAD, JUD. ARAD CF nr. 363226, TOP nr. 363226
DATA 07/2025	DENUMIRE PLANSA SCHEMA TABLOU ELECTRIC GENERAL CANTINA - TG COD PLANSA: 16-IE